



**LEAD & COPPER
IN DRINKING WATER TESTING REPORT**

Conducted for:

Greater Bergen Community Action
392 Main Street
Hackensack, New Jersey 07601

Conducted at:

Cliffside Park Head Start
263 Lafayette Avenue
Cliffside Park, New Jersey 07010

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: June 10, 2019

MES PROJECT NO.: 19-03619

Prepared by:

**Gary Clare
Environmental Scientist**

Signed for the Company by:

**John H. Chiaviello
Vice President**

4.0 TABLES OF SAMPLE RESULTS

The following table presents all lead and copper sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
CPHS-01	First Floor Girls Bathroom-Middle Sink	2.3	Pass	Pass	366	Pass
CPHS-02	First Floor Boys Bathroom-Middle Sink	2	Pass	Pass	92	Pass
CPHS-03	Kitchen Sink- Sink Side B	2.1	Pass	Pass	102	Pass
CPHS-04	Kitchen Sink- Sink Side D	11.1	Pass	Pass	384	Pass
CPHS-05	Gym- Girls Bathroom-Left Sink	0.8	Pass	Pass	46	Pass
CPHS-06	Gym- Boys Bathroom-Left Sink	1.5	Pass	Pass	116	Pass
CPHS-07	3 rd Floor Girls Bathroom-Left Sink	8.5	Pass	Pass	542	Pass
CPHS-08	Adult Bathroom- Sink-3 rd Floor	1.6	Pass	Pass	93	Pass
CPHS-09	4 th Floor- Adult Bathroom- Sink	1.2	Pass	Pass	40	Pass
CPHS-10	Service Line-2 Minute Flush	3.6	Pass	Pass	37	Pass
CPHS-11	Room 104 Bathroom Sink	1.2	Pass	Pass	84	Pass
CPHS-12	Room 107 Classroom Sink	9.6	Pass	Pass	87	Pass
CPHS-13	Room 107 Bathroom B4 Sink	< 0.5	Pass	Pass	37	Pass
CPHS-14	Nurse's Office Bathroom Sink	6.6	Pass	Pass	36	Pass