



**LEAD & COPPER
IN DRINKING WATER TESTING REPORT**

Conducted for:

Greater Bergen Community Action
392 Main Street
Hackensack, New Jersey 07601

Conducted at:

Bergenfield Head Start
100 Portland Avenue
Bergenfield, New Jersey 07621

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: June 10, 2019

MES PROJECT NO.: 19-03619

Prepared by:

**Gary Clare
Environmental Scientist**

Signed for the Company by:

**John H. Chiaviello
Vice President**

4.0 TABLES OF SAMPLE RESULTS

The following table presents all lead and copper sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
BHS-01	Kitchen- Sink	< 0.5	Pass	Pass	67	Pass
BHS-02	Water Fountain Outside Kitchen	< 0.5	Pass	Pass	522	Pass
BHS-03	Room 6- Porcelain Sink	< 0.5	Pass	Pass	163	Pass
BHS-04	Room 7- Bathroom Sink	< 0.5	Pass	Pass	88	Pass
BHS-05	Room 9- Porcelain Sink	0.8	Pass	Pass	31	Pass
BHS-06	Room 8- Porcelain Sink	< 0.5	Pass	Pass	122	Pass
BHS-07	Room 5- Porcelain Sink	1.8	Pass	Pass	87	Pass
BHS-08	Room 8- Bathroom Sink	< 0.5	Pass	Pass	123	Pass
BHS-09	Bathroom Between Rooms 3 & 4- Middle Sink	0.8	Pass	Pass	75	Pass
BHS-10	Room 2 Bathroom- Middle Sink	< 0.5	Pass	Pass	100	Pass
BHS-11	Handicap Bathroom	< 0.5	Pass	Pass	88	Pass
BHS-12	Bathroom Between Rooms 9 & 10- Left Sink	0.8	Pass	Pass	216	Pass
BHS-13	Bathroom Between Rooms 5 & 6- Left Sink	1.1	Pass	Pass	303	Pass
BHS-14	Room 10- Porcelain Sink	0.9	Pass	Pass	31	Pass
BHS-15	2 nd Floor Bathroom Sink	< 0.5	Pass	Pass	168	Pass
BHS-16	Service Line- 2 Minute Flush	0.6	Pass	Pass	43	Pass