



**LEAD & COPPER  
IN DRINKING WATER TESTING REPORT**

*Conducted for:*

Greater Bergen Community Action  
392 Main Street  
Hackensack, New Jersey 07601

*Conducted at:*

Michael's Energy Factory Head Start  
101 Oliver Street  
Paterson, New Jersey 07504

*Submitted by:*

McCabe Environmental Services, L.L.C.  
464 Valley Brook Avenue  
Lyndhurst, New Jersey 07071

**REPORT DATE:** June 10, 2019

**MES PROJECT NO.:** 19-03619

*Prepared by:*

**Gary Clare  
Environmental Scientist**

*Signed for the Company by:*

**John H. Chiaviello  
Vice President**

**4.0 TABLES OF SAMPLE RESULTS**

The following table presents all lead sample results in order of sample identification:

Sample ID	Sample Location	Lead Result (ppb)	Lead Exceeds (MCL 15 ppb)	Lead Exceeds (MCL 20 ppb)	Copper Result (ppb)	Copper Exceeds (MCL 1300 ppb)
MEF-01	Room IT-1 Low Sink	< 0.5	Pass	Pass	124	Pass
MEF-02	Room IT-2 Low Sink	< 0.5	Pass	Pass	246	Pass
MEF-03	Room IT-3 Sink	< 0.5	Pass	Pass	317	Pass
MEF-04	Room IT-4 Low Sink	1.8	Pass	Pass	234	Pass
MEF-05	Kitchen Sink	< 0.5	Pass	Pass	128	Pass
MEF-06	Room 104 Low Sink	1.1	Pass	Pass	129	Pass
MEF-07	Room 103 Low Sink	< 0.5	Pass	Pass	111	Pass
MEF-08	Room 101 Low Sink	0.6	Pass	Pass	138	Pass
MEF-09	Room 102 Low Sink	< 0.5	Pass	Pass	117	Pass
MEF-10	Room 105 Low Sink	3.3	Pass	Pass	165	Pass
MEF-11	Room 106 Low Sink	1.4	Pass	Pass	115	Pass
MEF-12	Room 203 Low Sink	0.8	Pass	Pass	143	Pass
MEF-13	Room 204 Low Sink	0.6	Pass	Pass	113	Pass
MEF-14	Room 201 Low Sink	0.6	Pass	Pass	168	Pass
MEF-15	Room 202 Low Sink	0.7	Pass	Pass	199	Pass
MEF-16	Room 206 Low Sink	0.9	Pass	Pass	152	Pass
MEF-17	Room 205 Low Sink	0.7	Pass	Pass	194	Pass
MEF-18	Service Line- 2 Minute Flush	< 0.5	Pass	Pass	63	Pass